



FORM 196
Rev. 09/20

COUNTY OF LOS ANGELES FIRE DEPARTMENT FIRE PREVENTION DIVISION

Fire Prevention Engineering
5823 Rickenbacker Road
Los Angeles, CA 90040
Telephone (323) 890-4125 Fax (323) 890-4129

Information on Fire Flow Availability for Building Permit

For All Buildings Other Than One and Two Family Dwellings (R-3), Townhomes, and Accessory Dwelling Unit's

INSTRUCTIONS:

Complete parts I & II:

Verifying fire flow, fire hydrant location and fire hydrant size.

PROJECT INFORMATION (To be completed by applicant)

PART I

Building Address: _____

City or Area: _____ APN: _____

Nearest Cross Street: _____

Distance of Nearest Cross Street
to Property Line: _____

Applicant: _____ Telephone: () _____

Address: _____

City: _____

Occupancy (Use of Building): _____ Fire Sprinklered: Yes No

Type of Construction: _____

Square Footage: _____ Number of Stories: _____

Applicant's Signature

Date

PART II

**INFORMATION ON FIRE FLOW AVAILABILITY
(Part II to be completed by Water Purveyor)**

Location of hydrant _____

_____ Hydrant Number _____

Distance from Nearest Property Line _____ Size of Hydrant _____ Size of Water main _____

Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____

Fire Flow at 20 PSI _____ Duration _____ Flow Test Date / Time _____
 Hydraulic model

Location of hydrant _____

_____ Hydrant Number _____

Distance from Nearest Property Line _____ Size of Hydrant _____ Size of Water main _____

Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____

Fire Flow at 20 PSI _____ Duration _____ Flow Test Date / Time _____
 Hydraulic model

(Check box if Simultaneous/ Dual flow test was performed) Combined flow at 20 psi _____

Location of hydrant _____

_____ Hydrant Number _____

Distance from Nearest Property Line _____ Size of Hydrant _____ Size of Water main _____

Static PSI _____ Residual PSI _____ Orifice size _____ Pitot _____

Fire Flow at 20 PSI _____ Duration _____ Flow Test Date / Time _____
 Hydraulic model

(Check box if Simultaneous/ Triple flow test was performed) Combined flow at 20 psi _____

Water Purveyor

Signature

Phone Number

Date

Title

This Information is Considered Valid for Twenty Four Months

Fire Department approval of building plans shall be required prior to the issuance of a Building Permit by the jurisdictional Building Department. Any deficiencies in water systems will need to be resolved by the Fire Prevention Division only prior to this department's approval of building plans.